



Finished Water Quality Summary **December 2022**

Flow	TOTAL	AVERAGE	MAXIMUM	MINIMUM
Process Flow (MGD)	440.7	14.2	18.2	12.1
Physical Properties	MCL/SMCL(a)			
pH (s.u.)	6.9 - 9.0(a)	8.03	8.10	7.93
Sp. Conductance (umhos)		420		
Total Hardness (mg/l) as CaCO ₃		160		
Calcium (mg/l) as Ca		42.6		
Metals				
Arsenic (ug/l)	10	7.85	8.72	7.32
Magnesium (mg/l)		13.1		
Sodium (mg/l)		23.4		
Aluminum (ug/l)	50-200(a)	4.32		
Inorganic Non-metals (mg/l)				
Chloride		11.3		
Fluoride	4	0.48		
Nitrate	10	0.34		
Sulfate	250(a)	68.3		
Alkalinity as CaCO ₃		136	146	130
Free Chlorine		1.14	1.20	1.11
Bacteria				
Total Coliform (col/100 ml)	Absent	0	0	0

Definitions	
MCL	Maximum Contaminant Level
SMCL(a)	Secondary Drinking Water Standards set by the Environmental Protection Agency
ND	Non Detect